



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001  
Revision 0: 2025-10-14  
Page 1 of 7

Oskorp  
FL41789

Nemo|cert.

353 Christian Street, Unit 12b  
Oxford, CT 06478  
(475) 888-CERT (2378)  
[www.nemocert.com](http://www.nemocert.com)

INSPECT

CERTIFY

EVALUATE

VALIDATE

QUALIFY

## NEMO EVALUATION REPORT (NER)



Oskorp

**Oskorp**  
3838 Tamiami Trail N #416  
Naples, FL 34103  
**+91 (972) 773-7448**

**SUBJECT:** Platina Underlayments

**SCOPE:** This NEMO Evaluation Report (henceforth 'NER') is issued under F.A.C. [Rule 61G20-3](#) and the applicable rules and regulations governing Product Approval of construction materials in the State of Florida and ISO/IEC 17065 via [NEMO|cert.](#) NEMO Evaluations has evaluated the product described herein for compliance with the [Code sections](#) noted herein.

**CODE:** 2024 International Building Code  
2024 International Residential Code  
2023 Florida Building Code, 8<sup>th</sup> Edition  
2023 Florida Building Code, Residential, 8<sup>th</sup> Edition

**FBC JURISDICTION:** Non-HVHZ and HVHZ

**NEMO CATEGORY:** Steep Slope

**FBC CATEGORY:** Roofing

**FBC SUB-CATEGORY:** Underlayment

**CSI DIVISION:** 07 00 00 Thermal and Moisture Protection  
07 30 05 Roofing Felt and Underlayment

**METHOD:** Method 2, Option A – Non-Codified Material, Evaluation by Evaluation Entity

**COMPLIANCE STATEMENT:** **Platina Underlayments**, as produced by **Oskorp**, have demonstrated compliance with the [Code sections](#) noted herein through testing in accordance with the referenced Standards, rational analysis and an ongoing quality assurance program. Compliance is subject to the [Installation Requirements](#) and [Limitations of Use](#) set forth herein.

**QUALITY ASSURANCE:** Evidence of current quality assurance shall be listing and labeling in accordance with the requirements of [NEMO|cert.](#)

**CONTINUED COMPLIANCE:** This NER is valid until such time the named product(s) change, the referenced Quality Assurance changes, or the evaluated Code provisions change. NEMO Evaluations require, at minimum, a complete review of this NER with each 3-year Code Cycle.

**BUILDING PERMIT REQUIREMENTS:** As required by the Building Official or Authority Having Jurisdiction to evaluate the installation of this product.

**ADVERTISEMENT:** "NEMO Evaluated" may be displayed in advertising literature. If any portion of the NER is displayed, it shall be displayed in its entirety.

**CERTIFICATION OF INDEPENDENCE:**

- ✓ NEMO CERT, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
- ✓ NEMO CERT, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
- ✓ This is a building code evaluation. NEMO CERT, LLC is not, in any way, the Designer of Record for any project on which this NER, or previous versions thereof, is/was used for permitting or design guidance.





# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001

Revision 0: 2025-10-14

Page 2 of 7

Oskorp

FL41789



ISO/IEC 17065



ACCREDITED

Product Certification Agency

PCA-145

## 1. CODES, PROPERTIES AND STANDARDS:

| CODE   | SECTION  | PROPERTY                      | STANDARD        |
|--|--|-------------------------------|-----------------|
| 2024 International Building Code                                 | 104.2.1  | Listed compliance             | AC48, AC188     |
|  | 104.2.3.6.1  | Evaluation Reports            | ISO/IEC 17065   |
|  | 1507.1.1   | Material standard (alternate) | ASTM D226       |
|  | 1507.1.1, 1507.2.8.2, 1507.2.8.3, 1507.3.9, 1507.5.7, 1507.8.8, 1507.9.9 | Material standard             | ASTM D1970      |
|  |  |                               |                 |
| 2024 International Residential Code                              | R104.2.1   | Listed compliance             | AC48, AC188     |
|  | R104.2.2.6.1   | Evaluation Reports            | ISO/IEC 17065   |
|  | R905.1.1   | Material standard (alternate) | ASTM D226       |
|  | R905.1.1, R905.2.8.2   | Material standard             | ASTM D1970      |
| 2023 Florida Building Code, 8 <sup>th</sup> Edition              | 1507.1.1, 1518.2, TAS 110  | Material standard (alternate) | ASTM D226       |
|  | 1507.1.1, 1507.2.9.2, 1507.2.9.3, 1518.2, TAS 110                        | Material standard (alternate) | ASTM D1970      |
|  | 1507.3.3   | Material standard             | FRSA/TRI Manual |
| 2023 Florida Building Code, Residential, 8 <sup>th</sup> Edition | R905.1.1   | Material standard (alternate) | ASTM D226       |
|  | R905.1.1, R905.2.8.2, R905.2.8.5   | Material standard (alternate) | ASTM D1970      |
|  | R905.3.3   | Material standard             | FRSA/TRI Manual |

## 2. PRODUCTS:

**TABLE 1: EVALUATED UNDERLAYMENTS**

(NEMO Certified. Consult [Directory of Certified Products](#) for production location(s))

| PRODUCT              | MATERIAL STANDARD                        | DESCRIPTION   |
|----------------------|--|---|
| Platina Peel & Stick | ASTM D1970 <sup>1</sup><br>AC48<br>AC188 | Nominal 30-mil, self-adhering, synthetic roof underlayment, ice and water barrier material composed of a synthetic top facer and release film |

**TABLE 1B: TYPICAL NOMINAL PROPERTIES**

| PROPERTY  | STANDARD                 | RESULT                                       |
|---|--------------------------|--|
| Thickness   | ASTM D1970               | 31   |
| Tear resistance, lbf                                | ASTM D4073               | MD: 63, XMD: 58                              |
| Elongation at break (Fabric), %                     | ASTM D1970               | MD: 60, XMD: 96                              |
| Elongation at break (Film), %                       |                          | MD: 408, XMD: 434                            |
| Low temperature flexibility                         | ASTM D1970               | No cracking at -20°F                         |
| Tensile strength, lbf/in                            | AC188 / AC48             | MD: 39, XMD: 35                              |
| Cyclic elongation                                   | AC188 / AC48             | No cracking or delamination                  |
| Water vapor transmission, g/m <sup>2</sup> -24 hrs. | ASTM E96, Procedure B    | 86<br>(See <a href="#">Section 3.3.3</a> )   |
| Water vapor permeance, perms                        |                          | 12.5<br>(See <a href="#">Section 3.3.3</a> ) |
| Peel adhesion (to plywood), lbf/in.                 | AC 188 / AC48            | 4.7  |
| Sealability around nails                            | ASTM D1970               | No leakage                                   |
| Ultraviolet Exposure (UVE)                          | AC 188 / AC48, 210 hours | No visible damage or delamination            |
| Tensile strength, post-UVE, lbf/in                  | AC188 / AC48             | MD: 51, XMD: 40                              |
| Peel adhesion (to plywood), post-UVE, lbf/in.       | AC 188 / AC48            | 3.5  |
| Accelerated Aging (AA)                              | AC 188 / AC48, 25 cycles | No visible damage or delamination            |
| Tensile strength, post-AA, lbf/in                   | AC188 / AC48             | MD: 44, XMD: 37                              |
| Peel adhesion (to plywood), post-AA, lbf/in.        | AC 188 / AC48            | 5.3  |

<sup>1</sup> Agreement between purchaser and seller, as set forth in Section 4.3, Note 1 of ASTM D1970-17, should be established as to slip resistance.



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001  
Revision 0: 2025-10-14  
Page 3 of 7

Oskorp  
FL41789



### 3. INSTALLATION:

3.1 **Platina Underlayments** shall be installed in accordance with **Oskorp** published installation instructions, subject to the [Limitations of Use](#) noted herein. In case of conflict between published installation instructions and this NER, this NER governs.

3.1.1 The report holder's installation instructions shall be made available at the jobsite at all times during installation.

3.2 Substrates shall be in accordance with codified requirements to the satisfaction of the Authority Having Jurisdiction. Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application, and prime the substrate (if applicable).

#### 3.3 **IBC and IRC:**

3.3.1 **Platina Underlayments** shall be installed in compliance with the applicable code, this NER and the report holder's published installation instructions.

#### 3.3.2 **Ice and Water Barrier:**

When used as an ice and water barrier, **Platina** shall be installed in sufficient courses to extend upslope a minimum of 24-inches beyond the exterior wall plane (Reference: IBC 1507.1.2 or R905.1.2). Subsequently installed roof underlayments shall overlap the ice barrier.

#### 3.3.3 **Roof Underlayment:**

3.3.3.1 IBC: When used as a roof underlayment:

**Platina Underlayments** may be installed as an alternative to the codified ASTM D226 Type I or II underlayments prescribed in IBC 1507.1.1. **Platina** does not require mechanical attachment.

3.3.3.2 IRC: When used as a roof underlayment:

**Platina** may be installed in accordance with the codified ASTM D1970 underlayments prescribed in IRC R905.1.1.

3.3.3.3 When **Platina** is installed atop a base sheet, the base sheet shall comply with, and be attached in accordance with IBC Table 1507.1.1(3) or Table R905.1.1(3).

Refer to [Table 2A](#) herein for allowable roof covers and [Table 3](#) herein for allowable substrates.

#### 3.3.4 **Joint-Strips:**

Min. 4-inch wide strips of **Platina** may be installed in accordance with IBC 1507.1.1(1) or IRC R905.1.1(2).

#### 3.3.5 **Flashing:**

**Platina** may be used as flashing material where use of an ASTM D1970 compliant material is prescribed in IBC Chapter 15 or IRC Chapter 9. Flashing shall be installed in a water-shedding condition. When installed in concert with metal drip edge, **Platina** shall be installed atop eave metal and beneath rake metal.

#### 3.4 **FBC (non-HVHZ) and FBC Residential:**

3.4.1 Refer to Section 3.4.2 below for underlayments having prescriptive codified minimum attached requirements or [Section 4.7.2](#) herein for underlayment systems having maximum design pressures established in accordance with FBC [1504.2.1.4](#).

3.4.2 Prescriptive Underlayment Systems for use in NON-TILE applications:

3.4.2.1 **CODE REFERENCE:** [1507.1.1.1](#) or [R905.1.1.1](#), **Option 1:**

**APPLICATION:** Underlayment adhered to deck

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction.

**UNDERLAYMENT:** **Platina** self-adhered in accordance with FBC Section 1507.1.1.1(1) or R905.1.1.1(1) and [back-nailed](#) in accordance with the manufacturer's requirements.

**SURFACING:** FBC Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in [Table 2B](#) herein.



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001  
Revision 0: 2025-10-14  
Page 4 of 7

Oskorp  
FL41789



3.4.2.2

**CODE REFERENCE:** [1507.1.1.1](#) or [R905.1.1.1](#), **Option 2:**  
**APPLICATION:** Self-adhering strips to deck-joints followed by underlayment mechanically attached to deck

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction  
**SECONDARY WATER BARRIER:** Min. 3 3/4-inch wide strips of **Platina** self-adhered over joints of the roof deck prior to installation of subsequent layer(s) in accordance with FBC Section 1507.1.1.1(2) or R905.1.1.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped.  
**UNDERLAYMENT:** FBC Approved, ASTM D226 Type II, ASTM D4869 Type III or IV, ASTM D6757 or ASTM D8257 underlayment with a minimum 4-inch side lap and 6-inch end lap, mechanically fastened to deck accordance with FBC Table 1507.1.1.1 or Table R905.1.1.1.  
**SURFACING:** FBC Approved prepared roof cover, subject to the limitations in FBC Table 1507.1.1.1 or Table R905.1.1.1.

3.4.2.3

**CODE REFERENCE:** [1507.1.1.1](#) or [R905.1.1.1](#), **Option 1 combined with Option 2 or 3:**  
**APPLICATION:** Optional self-adhering strips to deck-joints followed by base sheet mechanically fastened to deck followed by underlayment adhered to base sheet

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction  
**SECONDARY WATER BARRIER:** (Optional) Min. 3 3/4-inch wide strips of **Platina** self-adhered over joints of the roof deck prior to installation of subsequent layer(s) in accordance with FBC Section 1507.1.1.1(2) or R905.1.1.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped.  
**BASE SHEET:** One (1) layer of FBC Approved, ASTM D226 Type II, ASTM D4869 Type III or IV or ASTM D8257 underlayment in accordance with FBC Table 1507.1.1.1 or Table R905.1.1.1, with a minimum 4-inch side lap and 6-inch end lap or two (2) layers of FBC Approved, ASTM D226 Type II, ASTM D4869 Type III or IV or ASTM D8257 in accordance with FBC Section 1507.1.1.1(3) or R905.1.1.1(3), mechanically fastened to deck  
**FASTENERS:** Min. 0.083-inch diameter annular ring or deformed shank nails with metal or plastic caps with a nominal cap diameter of not less than 1-inch and minimum thickness as follows. The nail shall be of sufficient length to penetrate through the roof sheathing, or not less than 0.75-inch into the roof sheathing.  
**Note:** Metal caps are required where the ultimate design wind speed,  $V_{ult}$ , equals or exceeds 170 mph.  

| Cap Type               | Minimum thickness                   |
|------------------------|-------------------------------------|
| Metal cap              | 32 ga. sheet metal                  |
| Power-driven metal cap | 0.010-inch                          |
| Plastic cap            | 0.035-inch (outside edge thickness) |

  
**FASTENING:** Grid pattern of 12-inches between the overlaps and 6-inch spacing at the overlaps, in accordance with FBC Table 1507.1.1.1 or Table R905.1.1.1 or FBC Section 1507.1.1.1(3) or R905.1.1.1(3).  
**UNDERLAYMENT:** **Platina** self-adhered in accordance with FBC Section 1507.1.1.1(1) or R905.1.1.1(2) and [back-nailed](#) in accordance with the manufacturer's requirements.  
**SURFACING:** FBC Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in [Table 2B](#) herein.



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001  
Revision 0: 2025-10-14  
Page 5 of 7

Oskorp  
FL41789



## 3.5 FBC HVHZ (Broward and Miami-Dade Counties):

3.5.1 Refer to Section 3.5.2 below for underlayments having prescriptive codified minimum attachment requirements or [Section 4.7.2](#) herein for underlayment systems having maximum design pressures established in accordance with [TAS 103](#).

3.5.2 Prescriptive Underlayment Systems for use in NON-TILE applications:

### 3.5.2.1 CODE REFERENCE: [1518.2.1, Option 1:](#)

**APPLICATION:** Underlayment adhered to deck

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction.

**UNDERLAYMENT:** **Platina** self-adhered in accordance with FBC Section 1518.2.1(1) and back-nailed max. 12-inch o.c. using FBC HVHZ Approved nails and tin caps (FBC HVHZ [1517.5](#)).

**SURFACING:** FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in [Table 2B](#) herein.

### 3.5.2.2 CODE REFERENCE: [1518.2.1, Option 2:](#)

**APPLICATION:** Self-adhering strips to deck-joints followed by underlayment mechanically attached to deck

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction

**SECONDARY WATER BARRIER:** Min. 3 3/4-inch wide strips of **Platina** self-adhered over joints of the roof deck prior to installation of subsequent layer(s) in accordance with FBC Section 1518.2.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped.

**UNDERLAYMENT:** FBC HVHZ Approved, ASTM D226 Type II, ASTM D4869 Type III or IV or ASTM D8257 underlayment with a minimum 4-inch side lap and 6-inch end lap, mechanically fastened to deck in accordance with FBC Table 1518.2.1.

**SURFACING:** FBC HVHZ Approved prepared roof cover, subject to the limitations in FBC Table 1518.2.1.

### 3.5.2.3 CODE REFERENCE: [1518.2.1, Option 1 combined with Option 2 or 3:](#)

**APPLICATION:** Optional self-adhering strips to deck-joints followed by base sheet mechanically fastened to deck followed by underlayment adhered to base sheet

**DECK DESCRIPTION:** Code-minimum wood deck to the satisfaction of the Authority Having Jurisdiction

**SECONDARY WATER BARRIER:** (Optional) Min. 3 3/4-inch wide strips of **Platina** self-adhered over joints of the roof deck prior to installation of subsequent layer(s) in accordance with FBC Section 1518.2.1(2). Do not overlap end-joints or T-joints. All end-joints and T-joints shall be butted firmly side by side, flush with each other but not overlapped.

**BASE SHEET:** One (1) layer of FBC Approved, ASTM D226 Type II, ASTM D4869 Type III or IV or ASTM D8257 underlayment in accordance with FBC Table 1518.2.1, with a minimum 4-inch side lap and 6-inch end lap and two (2) layers of FBC Approved, ASTM D226 Type II, ASTM D4869 Type III or IV or ASTM D8257 underlayment in accordance with FBC Section 1518.2.1(3), mechanically fastened to deck

**FASTENING:** FBC HVHZ Approved nails and tin caps (FBC HVHZ [1517.5](#)), grid pattern of 12-inches between the overlaps and 6-inch spacing at the overlaps, in accordance with FBC Table 1518.2.1 or FBC Section 1518.2.1(3).

**UNDERLAYMENT:** **Platina** self-adhered in accordance with FBC Section 1518.2.1(1) and back-nailed max. 12-inch o.c. using FBC HVHZ Approved nails and tin caps (FBC HVHZ [1517.5](#)).

**SURFACING:** FBC HVHZ Approved asphalt shingles, metal roof panels or metal shingles, slate or slate type shingles, subject to the allowable roof covers in [Table 2B](#) herein.

## 3.6 Product-Specific Notes

Platina is vapor permeable. Care shall be taken to ensure the roof system design takes the vapor permeable nature into account.



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001  
Revision 0: 2025-10-14  
Page 6 of 7

Oskorp  
FL41789



## 4. LIMITATIONS OF USE:

- 4.1 This is a building code evaluation. NEMO CERT, LLC is not, in any way, the Designer of Record for any project on which this NER, or previous versions thereof, is/was used for permitting or design guidance. NERs are not to be construed as representing any attributes not specifically listed, nor are NERs to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by NEMO CERT, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.
- 4.2 This NER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with the applicable Code requirements to the satisfaction of the Authority Having Jurisdiction.
- 4.3 **Platina Underlayments** may be used with any prepared roof cover where the product is specifically referenced within approval documents. If not listed, a request may be made to the Authority Having Jurisdiction for approval based on this NER combined with supporting data for the prepared roof covering.
- 4.4 **Fire Classification:**  
This NER does not include evaluation of fire classification. Refer to **IBC 1505, IRC R902, FBC 1505 or FBC Residential R902** for requirements and limitations regarding roof assembly fire classification. Refer to **IBC 2603, IRC R303, FBC 2603, or FBC Residential R316** for requirements and limitations concerning the use of foam plastic insulation.
- 4.5 Platina is highly vapor permeable. Care shall be taken to ensure the roof system design takes the vapor permeable nature into account.
- 4.5 **Allowable Roof Covers:**  
Table 2 lists allowable roof cover types, subject to fire classification documentation set forth in [Section 4.4](#) herein (if applicable).

| TABLE 2A: ROOF COVER OPTIONS, IBC/IRC |                              |                |                  |                 |                  |
|---------------------------------------|------------------------------|----------------|------------------|-----------------|------------------|
| UNDERLAYMENT                          | ROOF COVER                   | IBC SECTION(S) |                  | IRC SECTION(S)  |                  |
|                                       |                              | SECTION        | USE              | SECTION         | USE              |
| Platina                               | Asphalt Shingles             | 1507.2         | Yes <sup>2</sup> | R905.2          | Yes <sup>2</sup> |
|                                       | Roof Tile                    | 1507.3         |                  | R905.3          |                  |
|                                       | Metal Shingles or Panels     | 1507.4, 1507.5 |                  | R905.4, R905.10 |                  |
|                                       | Slate or Slate-Type Shingles | 1507.7         |                  | R905.6          |                  |
|                                       | Wood Shingles or Shakes      | 1507.8, 1507.9 |                  | R905.7, R905.8  |                  |

| TABLE 2B: ROOF COVER OPTIONS, FBC |                              |                                 |                  |                     |                  |
|-----------------------------------|------------------------------|---------------------------------|------------------|---------------------|------------------|
| UNDERLAYMENT                      | ROOF COVER                   | FBC AND FBC-R SECTION(S)        |                  | FBC HVHZ SECTIONS   |                  |
|                                   |                              | SECTION                         | USE              | SECTION             | USE              |
| Platina                           | Asphalt Shingles             | 1507.2, R905.2                  | Yes <sup>3</sup> | RAS 115, 1518.2.1   | Yes              |
|                                   | Roof Tile                    | 1507.3, R905.3                  | No               | RAS 118, 119 or 120 | No               |
|                                   | Metal Shingles or Panels     | 1507.4, 1507.5, R905.4, R905.10 | Yes <sup>3</sup> | RAS 133, 1518.2.1   | Yes              |
|                                   | Slate or Slate-Type Shingles | 1507.7, R905.6                  | Yes <sup>3</sup> | 1518.2.1            | Yes              |
|                                   | Wood Shingles or Shakes      | 1507.8, 1507.9, R905.7, R905.8  | Yes <sup>3</sup> | RAS 130, 1518.10    | Yes <sup>4</sup> |

- 4.5.1 In addition to the codified roof cover options noted above, allowable roof covers include synthetic or composite shingles, slate or shakes holding current Product Approval (statewide or local) to the satisfaction of the Authority Having Jurisdiction.

<sup>2</sup> For **IBC/IRC**, product used as ASTM D1970 compliant material or as alternate to ASTM D226, Type I or Type II felt. For roof tile, use is limited to mechanically fastened tile.

<sup>3</sup> For **FBC non-HVHZ**, product used as ASTM D1970 and FRSA/TRI Manual compliant material. For wood shakes and wood shingles, limited to use as joint-strips per FBC 1507.1.1.1(2), 1518.2.1(2) or R905.1.1.1(2) or as cap sheet atop mechanically attached, FBC Approved ASTM D226 Type II or ASTM D4869 Type III or IV base sheet.

<sup>4</sup> For **FBC HVHZ**, product used as ASTM D1970 compliant material. For wood shakes and shingles, product is limited to use per RAS 130.



# NEMO EVALUATIONS REPORT

Report No.: NER-OSK-001

Revision 0: 2025-10-14

Page 7 of 7

Oskorp

FL41789



ISO/IEC 17065



ACCREDITED

Product Certification Agency

PCA-145

## 4.6 Allowable Substrates:

| TABLE 3: SUBSTRATE OPTIONS FOR ADHERED UNDERLAYMENTS |               |  |        |             |
|--|---------------|--|--------|-------------|
| UNDERLAYMENT   | APPLICATION   | SUBSTRATES (DESIGNED TO MEET WIND LOADS FOR PROJECT) |        |             |
|  |               | TYPE   | PRIMER | MATERIAL(S) |
| Platina  | self-adhering | Deck / sheathing                                     | None   | Plywood     |

## 4.7 Attachment Limitations:

4.7.1 For use under the IBC and IRC and for use in NON-TILE applications under the FBC and FBC Residential, refer to [Section 3](#) herein and the applicable Code requirements.

## 4.8 Exposure Limitations:

| TABLE 5: EXPOSURE LIMITATIONS |   |                         |
|-------------------------------|---|-------------------------|
| UNDERLAYMENT                  | PREPARED ROOF COVER INSTALLATION TYPE (OVERTOP OF UNDERLAYMENT) | MAXIMUM EXPOSURE (DAYS) |
| Platina                       | Mechanically attached   | 30                      |

4.10 All components in the roof assembly shall have quality assurance audit in accordance with F.A.C. [Rule 61G20-3](#). Refer to the Product Approval of the component manufacturer for components mentioned herein that are produced by a Product Manufacturer other than this report holder.

- END OF NER -